



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DG-4550BL0160

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Pegler Yorkshire Group Ltd St. Catherine's Avenue, GB- Doncaster DN4 8DF
Distributor <i>Vertreiber</i>	VSH Fittings BV Oude Amersfoortseweg 99, NL-1212 AA Hilversum
Product Category <i>Produktart</i>	installation systems and system joints: compression joint for metallic gas pipes (8531)
Product Description <i>Produktbezeichnung</i>	Compression joint for metallic gas pipes
Model <i>Modell</i>	VSH XPress Copper Gas
Test Reports <i>Prüfberichte</i>	laboratory control test: 120001607-17 from 06.06.2017 (MPM) laboratory control test: 120001141-17 from 31.05.2017 (MPM)
Test Basis <i>Prüfgrundlagen</i>	DVGW G 5614 (01.12.2013)

Date of Expiry / File No. 05.05.2023 / 18-0207-GNV
Ablaufdatum / Aktenzeichen

22.06.2018 Fk A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Gas Category <i>Gasart</i>	Remarks <i>Bemerkungen</i>
fuel gases according to G260	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
VSH XPress Copper Gas	nominal pressure rating: PN 5/GT1 nominal diameter: DN 15	
VSH XPress Copper Gas	nominal pressure rating: PN 5/GT1 nominal diameter: DN 18	
VSH XPress Copper Gas	nominal pressure rating: PN 5/GT1 nominal diameter: DN 22	
VSH XPress Copper Gas	nominal pressure rating: PN 5/GT1 nominal diameter: DN 28	
VSH XPress Copper Gas	nominal pressure rating: PN 5/GT1 nominal diameter: DN 35	
VSH XPress Copper Gas	nominal pressure rating: PN 5/GT1 nominal diameter: DN 42	
VSH XPress Copper Gas	nominal pressure rating: PN 5/GT1 nominal diameter: DN 54	

Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>
Bogen 90°, i/i und i/a	da: 15, 18, 22, 28, 35, 42, 54 mm
Bogen 45°, i/i und i/a	da: 15, 18, 22, 28, 35, 42, 54 mm
T-Stück, gleichgängiger Abg.	da: 15, 18, 22, 28, 35, 42, 54 mm
T-Stück, reduzierter Abg.	da: 18/15, 22/15, 22/18, 28/15, 28/18, 28/22, 35/22, 35/28, 42/28, 42/35, 54/35, 54/42, 22/15/15, 22/22/15 mm
Ü-Stück, AG/Pressende	da: 15, 18, 22, 28, 35, 42, 54 mm; AG R... EN 10226-1
Ü-Stück, IG/Pressende	da: 15, 18, 22, 28, 35, 42, 54 mm; IG Rp... EN 10226-1
(Schiebe-)Muffe	da: 15, 18, 22, 28, 35, 42, 54 mm
Reduzier Stück/- Muffe	da: 15/14, 15/16, 18/15, 18/16, 22/15, 22/18, 28/15, 28/18, 28/22, 35/22, 35/28, 42/22, 42/28, 42/35, 54/35, 54/42 mm
Überbogen, i/i und i/a	da: 15, 18, 22 mm
Pressverschraubung	da: 15, 18, 22, 28, 35, 42, 54 mm; screw connection conical sealing to DIN 3436 (E)
Halbe Verschraubung	da: 15, 22, 28, 35, 42, 54 mm; screw connection conical sealing to DIN 3436 (E)
Verschlusskappe	for da: 15, 18, 22, 28, 35, 42, 54 mm
Winkel 90° IG/PE	da: 15, 18, 22, 28, 35, 42, 54 mm with IG Rp...EN 10226-1
Winkel 90° AG/PE	da: 15, 18, 22, 28, 35, 42, 54 mm with AG Rp...EN 10226-1
T-Stück IG	da: 15, 18, 22, 28, 35, 42, 54 mm with IG Rp...EN 10226-1
Wandscheibe	da: 15, 18, 22 mm with IG Rp...EN 10226-1

certified Components

zertifizierte Bauteile / Werkstoffe

Registr. No. <i>Registrier-Nr.</i>	Component <i>Bauteil (Produktart)</i>	Model/Type <i>Modell/Typ</i>	Manufacturer <i>Hersteller</i>
NG-5112BQ0329	Sealing material made of elastomers for TH5/03/1/TH5/03/1 gas appliances		Superior Seals Ltd.
DG-5112BS0407	Sealing material made of elastomers for 70 HN 120 p/70 HN 120 p gas appliances		BodeDynamic GmbH

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

This certification are present pressing tools of the certificate holder.

The certificate holder carries guarantee out on the certified characteristics of the press connections on use of these pressing tools.

Permitted range of temperature: -20...+70 °C

Tube kind: copper-tube according to DVGW Arbeitsblatt GW 392

Nominal pressure rating: PN 5/GT 1;

GT 1: The requirements of the higher thermal resistance (HTB) are fulfilled to nominal pressure rating PN 1.