



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-8511BU0144

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Pegler Yorkshire Group Ltd St. Catherine's Avenue, GB- Doncaster DN4 8DF
Distributor <i>Vertreiber</i>	Pegler Yorkshire SDH 46, rue de l'industrie, F-45550 Saint-Denis de L'Hotel
Product Category <i>Produktart</i>	installation systems and system joints: pipe joint for pipes in drinking water installation systems (8511)
Product Description <i>Produktbezeichnung</i>	system joints as plug in fitting made of copper for pipes made of copper according to DVGW working sheet GW 392
Model <i>Modell</i>	Tectite Sprint
Test Reports <i>Prüfberichte</i>	laboratory control test: 120001607-18 from 04.09.2018 (MPM) type testing: 120001607-14 from 03.07.2014 (MPM) type testing: 120003296 from 01.04.2009 (MPM)
Test Basis <i>Prüfgrundlagen</i>	DVGW W 534 (01.05.2004) DVGW CERT ZP 8500 (09.03.2017) UBA METALLE (21.11.2018) UBA ELASTOM (16.03.2016) DVGW W 270 (01.11.2007)

Date of Expiry / File No. 01.04.2024 / 19-0185-WNV
Ablaufdatum / Aktenzeichen

25.03.2019 LE A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
Tectite Sprint	diameter: 12 mm	type: M-MM
Tectite Sprint	diameter: 15 mm	type: M-MM
Tectite Sprint	diameter: 18 mm	type: M-MM
Tectite Sprint	diameter: 22 mm	type: M-MM
Tectite Sprint	diameter: 28 mm	type: M-MM

certified Components**zertifizierte Bauteile / Werkstoffe**

Registr. No. Registr.-Nr.	Component Bauteil (Produktart)	Model/Type Modell/Typ	Manufacturer Hersteller
NW-5253BP5648	sealing material for drinking water installations	EP 1/1/5/EP 1/1/5	Superior Seals Ltd.

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

The type testing was made with pipes made of copper according to DVGW working sheet GW 392.